PANELBOARD: D2N1B

BUS SIZE: 600 AMPS | MAIN: (X)MCB ( )MLO | SERVICE RATED: ( ) YES (X) NO
VOLTAGE: 208 Y/120V 3PH,4W | MCB AMPS: 500A MCB
NEUTRAL: (X)100% ( )200% ( )NONE | LOCATION: 2 ND FLOOR ELECTRIC ROOM
ISOLATED GND BUS: ( )YES X)NO | MOUNTING: SURFACE
SHORT CIR. CURRENT RATING 22K | TVSS: ( ) YES (X) NO

DIRECTORY	WATTS OF LOAD L1	L2	L3	CKT BKR AMPS	POLES		CKT BKR AMPS	WATTS OF LOAD L1	L2	L3	DIRECTORY
PANEL B2C				200	1	2	200				PANEL B3C
					3	4					
					5	6					
SPARE				200	7	8	200				SPARE
					9	10					
					11	12					
SPACE					13	14					SPACE
					15	16					
					17	18					
SPACE					19	20					SPACE
					21	22					
					23	24					
SPACE					25	26					SPACE
					27	28					
					29	30					
SUBTOTAL	0	0	0					0	0	0	SUBTOTAL

NOTES:
FED VIA TRANSFORMER T2 150KVA

TOTAL WATTS L1: 0
TOTAL WATTS L2: 0
TOTAL WATTS L3: 0
TOTAL WATTS: 0
TOTAL AMPS @ 100%: 0 AMPS
TOTAL AMPS @ 125%: 0 AMPS

TOTAL PANEL RECPT LOAD = 0 WATTS

PANELBOARD B3C

BUS SIZE: 200 AMPS | MAIN: ( )MCB (X)MLO | SERVICE RATED ( ) YES (X) NO
VOLTAGE: 208 /120V 3PH,4W | MAIN AMPS:
NEUTRAL: (X)100% ( )200% ( )NONE | LOCATION: THIRD FLOOR ELECTRIC ROOM
ISOLATED GND BUS: (X)YES ( )NO | MOUNTING: SURFACE
SHORT CIR. CURRENT RATING 22K | TVSS: ( ) YES (X) NO

DIRECTORY	WATTS OF LOAD L1	L2	L3	CKT BKR AMPS	POLES		CKT BKR AMPS	WATTS OF LOAD L1	L2	L3	DIRECTORY
SPARE				20	1	2	20				SPARE
SPARE				20	3	4	20				SPARE
SPARE				20	5	6	20				SPARE
SPARE				20	7	8	20				SPARE
SPARE				20	9	10	20				SPARE
SPARE				20	11	12	20				SPARE
SPARE				20	13	14	20				SPARE
SPARE				20	15	16	20				SPARE
SPARE				20	17	18	20				SPARE
SPARE				20	19	20	20				SPARE
					21	22					
					23	24					
SPARE				20	25	26	15				SPARE
					27	28					
SPACE					29	30					SPACE
SPACE					31	32					SPARE
SPACE					33	34					SPARE
SPACE					35	36					SPARE
SPACE					37	38					SPACE
SPACE					39	40					SPACE
SPACE					41	42					SPACE
SUBTOTAL	0	0	0					0	0	0	SUBTOTAL

NOTES:

TOTAL WATTS L1: 0
TOTAL WATTS L2: 0
TOTAL WATTS L3: 0
TOTAL WATTS: 0
TOTAL AMPS @ 100%= 0 AMPS
TOTAL AMPS @ 125%= 0 AMPS

TOTAL PANEL RECPT LOAD = 0 WATTS

PANELBOARD B2C

BUS SIZE: 200 AMPS | MAIN: ( )MCB (X)MLO | SERVICE RATED ( ) YES (X) NO
VOLTAGE: 208 /120V 3PH,4W | MAIN AMPS:
NEUTRAL: (X)100% ( )200% ( )NONE | LOCATION: SECOND FLOOR ELECTRIC ROOM 265
ISOLATED GND BUS: (X)YES ( )NO | MOUNTING: SURFACE
SHORT CIR. CURRENT RATING 22K | TVSS: ( ) YES (X) NO

DIRECTORY	WATTS OF LOAD L1	L2	L3	CKT BKR AMPS	POLES		CKT BKR AMPS	WATTS OF LOAD L1	L2	L3	DIRECTORY
SPARE				20	1	2	20				SPARE
SPARE				20	3	4	20				SPARE
SPARE				20	5	6	20				SPARE
SPARE				20	7	8	20				SPARE
SPARE				20	9	10	20				SPARE
SPARE				20	11	12	20				SPARE
SPARE				20	13	14	20				SPARE
SPARE				20	15	16	20				SPARE
SPARE				20	17	18	20				SPARE
SPARE				20	19	20	20				SPARE
					21	22					
					23	24					
SPARE				20	25	26	15				SPARE
					27	28					
SPACE					29	30					SPACE
SPACE					31	32					SPARE
SPACE					33	34					SPARE
SPACE					35	36					SPARE
SPACE					37	38					SPACE
SPACE					39	40					SPACE
SPACE					41	42					SPACE
SUBTOTAL	0	0	0					0	0	0	SUBTOTAL

NOTES:

TOTAL WATTS L1: 0
TOTAL WATTS L2: 0
TOTAL WATTS L3: 0
TOTAL WATTS: 0
TOTAL AMPS @ 100%= 0 AMPS
TOTAL AMPS @ 125%= 0 AMPS

TOTAL PANEL RECPT LOAD = 0 WATTS

LDa ARCHITECTURE & INTERIORS

Springfield Technical Community College
Facilites Upgrade - STCC Building 20
201025.00

Armory Square
Springfield, MA

LDa Architecture & Interiors, LLP
222 Third St.Suite 3212
Cambridge, Massachusetts 02142
tel: 617-621-1455 |fax: 617-621-1477
www.lda-architects.com

Rist Frost Shumway Engineering, P.C.
71 Water St
Laconia, NH 03246
P: 603.524.4647
F: 603.528.7653
www.rfsengineering.com

ISSUANCE:
PROGRESS SET

REVISION:

DATE: 02/25/11
SCALE: N/A
DRAWN: RAB
CHECKED: PLC

SHEET INFO:
PANEL BOARD SCHEDULE

E4.2