

Residence House Door Schedule - for bid 11-22-2011 - Revised for Addendum #1 12-2-2011

Area	Building	Floor	Door # Location	New Reader	New Door Contact	New ADA Door Operator	Existing Door Operator	Request to exit in hardware	Request To Exit Infrared	Local Alarm	Remove and Salvage Existing reader	Secure	Key switch to paddle	Hardware Group	Notes	Cable Requirements	Mounting Requirements
Lower Elm	150 Elm Street	1	Door 1	1	1	1				1				8	ADA Door	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	150 Elm Street	1	Door 2	1	1			1		1				6		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	150 Elm Street	B	Hatchway		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	150 Elm Street	1	Rear into kitchen		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Albright	1	Door 1	1	1			1		1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Albright	1	Door 2	1	1			1		1				5		18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Albright	B	Door 3	1	1			1		1	1			17		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Baldwin	1	Door 1	1	1			1		1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Baldwin	1	Door 2	1	1		1	1		1	1			9	ADA Door	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Baldwin	1	back door		1			1		1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Baldwin	B	side door to parking		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Baldwin	B	back door to porch		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Capen	1	Door 1	1	1			1		1				18		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Capen	1	Door 2	1	1	1		1		1			1	19	ADA Door	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Upper Elm	Capen	1	Door 3	1	1			1		1				18		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Capen	1	side door off ramp		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Capen	B	door to hatchway		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Green Street	Chapin	1	Door 1	1	1		1	1		1	1		1	20	ADA Door	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Green Street	Chapin	1	Door 2	1	1			1		1				2		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Chapin	1	back door toward pond		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Green Street	Chapin	1	Dining entrance		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Green Street	Chapin	B	door to hatchway		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Green Street	Chapin	1	French doors from LR to porch									1		ETR	Fixed no contact needed	No Cable Needed	No Mounting Hardware Needed
Green Street	Chapin	1	French doors from DR to ramp									1		ETR	Fixed no contact needed	No Cable Needed	No Mounting Hardware Needed
Lower Elm	Chase	G	Door 1	1	1			1		1				4		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Chase	G	Door 2	1	1		1	1		1	1		1	22	ADA Door	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Lower Elm	Chase	G	Door 3	1	1			1		1				23		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Chase	G	Door 4		2				1	1				ETR		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Chase	G	Door K	1	1			1		1				24		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Chase	G	kitchen door back toward Unity House		1				1	1				ETR	Keyed Staff Entrance	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Chase	G	double door to Mech room		2				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Chase	2	door to dining roof in back stair		1				1	1				ETR	Area Office Staff entrance.	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Chase	G	turret to storage area		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Chase	1	ext. door to back stair near Unity		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Chase	1	Door to Porch 1		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Chase	1	Door to Porch 2		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Comstock	1	Door 1	1	1			1		1	1			14		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Comstock	1	Door 2	1	1		1	1		1			1	15	ADA Door	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Quad	Comstock	1	Door 3	1	1			1		1				7		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Comstock	1	Door to back stairs on Dryads Green		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Comstock	1	french doors logia									1		ETR	Fixed no contact needed	No Cable Needed	No Mounting Hardware Needed
Quad	Comstock	1	french doors logia									1		ETR	Fixed no contact needed	No Cable Needed	No Mounting Hardware Needed
Quad	Comstock	1	side door to stairway		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Comstock	B	areaway door to basement		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Conway	1	Door 1	1	1	1		1		1				25	ADA Door	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Lower Elm	Conway	1	Door to common room		1				1	1						22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Conway	LL	Exit off right stairs		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Conway	LL	Exit off left stairs		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Cushing	1	Door 1	1	1			1		1	1			1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Cushing	1	Door 2	1	1			1		1				1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Cushing	1	Door 3	1	1	1		1		1				4	ADA Door	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Quad	Cushing	1	Exit from Stairway		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Cushing	1	Exit from Dining room		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Cushing	1	French door on LR									1		ETR		No Cable Needed	No Mounting Hardware Needed

Residence House Door Schedule - for bid 11-22-2011 - Revised for Addendum #1 12-2-2011

Area	Building	Floor	Door # Location	New Reader	New Door Contact	New ADA Door Operator	Existing Door Operator	Request to exit in hardware	Request To Exit Infrared	Local Alarm	Remove and Salvage Existing reader	Secure	Key switch to paddle	Hardware Group	Notes	Cable Requirements	Mounting Requirements
Quad	Cushing	2	Back door to outside stairs		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Cushing	roof	Roof door									1		ETR	Verify keying	No Cable Needed	No Mounting Hardware Needed
Campus Ctr	Cutter	1	Door 1	1	1		1			1	1		1	33	ADA Door	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Upper Elm	Davis Center	1	Door 1	1	1	1		1						4	Entrance to Elevator	18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Davis Center	1	Door 2	1	1			1		1				34	Mwangi Entrance	18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Dawes	1	Door 1	1	1			1		1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Dawes	1	Door 2	1	1			1		1				5	Koscher Kitchen	18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Dawes	1	Side Porch to LR		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Dawes	B	Side Porch to Parlor		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Dawes	B	Basement door side 1		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Dawes	B	Basement door side 2		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Duckett	1	Door 1	1	1			1		1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Duckett	1	Door 2	1	1			1		1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Duckett	1	Door 3	1	1	1		1		1	1			26	ADA Entrance	18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Lower Elm	Duckett	1	Door to basement		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Duckett	2	Side Door Elm Street		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Emerson	1	Door 1	1	1			1		1				1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Emerson	1	Door 2	1	1			1		1				1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Emerson	1	Door 3	1	1	1		1		1				3	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Quad	Emerson	1	Door 4	1	1	1		1		1				4	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Quad	Emerson	1	Door K	1	1			1		1				2		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Emerson	1	French Doors Dining									1		ETR	Install security screens	No Cable Needed	No Mounting Hardware Needed
Quad	Emerson	1	French Doors Dining									1		ETR	Install security screens	No Cable Needed	No Mounting Hardware Needed
Quad	Emerson	1	Exit from Stairway East		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Emerson	1	French Doors Living									1		ETR		No Cable Needed	No Mounting Hardware Needed
Quad	Emerson	1	French Doors Living									1		ETR		No Cable Needed	No Mounting Hardware Needed
Quad	Emerson	1	President's Guest Suite		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Emerson	roof	2 roof doors									2		ETR	Keyed for maintenance	No Cable Needed	No Mounting Hardware Needed
Quad	Emerson	B	Door to hatchway East		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Emerson	B	Door to hatchway West		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Gardiner	1	Door 1	1	1			1		1				1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Gardiner	1	Door 2	1	1			1		1				1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Gardiner	1	French door in Dining rm		2				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Gardiner	1	Back door to Kitchen		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Gardiner	1	Door off Living room									1		ETR		No Cable Needed	No Mounting Hardware Needed
Quad	Gardiner	2	Exit from stairway (2)		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Gardiner	B	Under Dining room		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Gardiner	1	Door off Living room		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Gillett	1	Door 1	1	1		1			1	1		1	3	ADA entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Lower Elm	Gillett	1	Door 2	1	1		1			1				3	ADA entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Lower Elm	Gillett		Door 3	1	1			1		1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Lower Elm	Gillett	B	Hatchway		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Haven	1	Door 1	1	1			1		1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Campus Ctr	Haven	1	Door 2	1	1		1			1	1		1	6	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Keypad - Single Gang
Campus Ctr	Haven	1	Side (by Kitchenette)		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Haven	1	HR Porch door		1				1	1				ETR			
Campus Ctr	Haven	B	Exit from back stairway		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Haven	B	Basement Door		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Hopkins	B	Door 1	1	1			1		1				7		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Campus Ctr	Hopkins	1	Door 2	1	1	1		1		1				8	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang

Residence House Door Schedule - for bid 11-22-2011 - Revised for Addendum #1 12-2-2011

Area	Building	Floor	Door # Location	New Reader	New Door Contact	New ADA Door Operator	Existing Door Operator	Request to exit in hardware	Request To Exit Infrared	Local Alarm	Remove and Salvage Existing reader	Secure	Key switch to paddle	Hardware Group	Notes	Cable Requirements	Mounting Requirements
Campus Ctr	Hopkins	1	Door 3	1	1		1	1		1			1	4	ADA Entrance - lower paddle	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Campus Ctr	Hopkins	1	Back side into stairway		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Hopkins	1	Side into kitchen		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Hopkins	1	Door to small porch on left									1		ETR		No Cable Needed	No Mounting Hardware Needed
Green Street	Hubbard	1	Door 1	1	1		1	1		1			1	9	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Green Street	Hubbard	1	Door 2	1	1			1	1					5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Hubbard	B	Door 3	1	1			1	1					6		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Hubbard	1	Door K	1	1			1	1					6		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Hubbard	1	Door at ramp		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
																22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Jordan	1	Door 1	1	1			1	1					1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Jordan	1	Door 2	1	1			1	1					1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Jordan	1	Door 3	1	1	1		1		1				4	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Quad	Jordan	2	Back into stairway 3		1			1	1					ETR	Reader eliminated per Res Life.	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Jordan	1	French doors into LR									1		ETR		No Cable Needed	No Mounting Hardware Needed
Quad	Jordan	1	Side Door into dining room		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Jordan	roof	Roof door									1		ETR		No Cable Needed	No Mounting Hardware Needed
Quad	King	1	Door 1	1	1		1	1		1			1	11	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Quad	King	1	Door 2	1	1			1	1					11		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	King	B	Door 3	1	1	1		1		1				8	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Quad	King	1	Door K	1	1			1	1					7		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	King	1	Door into dining room		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	King	1	Side door by study		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	King	1	In stairway to dumpster area		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	King	1	Back door to vestibule		1			1	1					ETR	Keyed Staff Entrance?	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Lamont	1	Door 1	1	1		1	1		1			1	9	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Upper Elm	Lamont	1	Door 2	1	1	1		1		1				16	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Upper Elm	Lamont	1	Door 3	1	1			1	1					1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Lamont	1	Door 4	1	1			1	1					16		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Lamont	1	Door K	1	1			1	1					13		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Lamont	1	French doors in main DR		2			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Lamont	1	Door into Living rm		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Lamont	1	Door into Host Dining rm		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Lamont	1	Loading Dock		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Lamont	B	Basement Door by Food Storage		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Lamont	B	Basement door by lounge		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Green Street	Lawrence	1	Door 1	1	1		1	1		1			1	9	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Green Street	Lawrence	1	Door 2	1	1			1	1					5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Lawrence	B	Door to Hatchway		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Green Street	Morris	1	Door 1	1	1		1	1		1			1	9	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Green Street	Morris	1	Door 2	1	1			1	1					5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Morris	B	Door to Hatchway		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Morrow	1	Door 1	1	1			1	1	1				1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Morrow	1	Door 2	1	1			1	1					1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Morrow	2	Door to stairs by storage rm		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Morrow	1	dining to exterior		2			1	1					ETR		No Cable Needed	No Mounting Hardware Needed
Quad	Morrow	1	Side doors into Living room		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Morrow	1	French doors into Living room									1		ETR		No Cable Needed	No Mounting Hardware Needed
Quad	Morrow	2	Door over LR to outside stairs		1			1	1					ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Morrow	B	Pass-thru to Wilson									1		ETR	Okay locked by staff	No Cable Needed	No Mounting Hardware Needed

Residence House Door Schedule - for bid 11-22-2011 - Revised for Addendum #1 12-2-2011

Area	Building	Floor	Door # Location	New Reader	New Door Contact	New ADA Door Operator	Existing Door Operator	Request to exit in hardware	Request To Exit Infrared	Local Alarm	Remove and Salvage Existing reader	Secure	Key switch to paddle	Hardware Group	Notes	Cable Requirements	Mounting Requirements
Upper Elm	Northrop	1	Door 1	1	1		1	1		1			1	3	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Upper Elm	Northrop	1	Door 2	1	1			1		1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Northrop	B	Door to Basement		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Park	1	Door 1	1	1		1	1		1			1	12	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Campus Ctr	Park	B	Door 2	1	1			1		1				13		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Campus Ctr	Park	B	Back door, Pond side		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Park	B	Lower Front Porch		1				1	1				ETR	Exit only? Change from current access	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Park Annex	1	Door 1	1	1			1		1				7		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Campus Ctr	Park Annex	1	Door 2	1	1	1		1		1				3	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Campus Ctr	Park Annex	B	Door to Hatchway		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Parsons	B	Door 1	1	1			1		1				27		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Parsons	B	Door 2	1	1			1		1				11		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Parsons		Door 3	1	1			1		1				6		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Parsons	B	Basement door to general stores		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Parsons	B	Basement door by waste rm		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Parsons	1	Door to external stairs		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Parsons	1	Back door to HR Living rm									1		ETR	No Cable Needed		No Mounting Hardware Needed
Upper Elm	Parsons Annex	1	Door 1	1	1			1		1				6		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Parsons Annex	1	Door 2	1	1	1		1		1				28	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Upper Elm	Parsons Annex	1	Porch off of Kitchen									1		ETR	Change to no Access?	No Cable Needed	No Mounting Hardware Needed
Upper Elm	Parsons Annex	2	2nd Floor Porch									1		ETR	Change to no Access?	No Cable Needed	No Mounting Hardware Needed
Quad	Scales	1	Door 1	1	1		1	1		1	1		1	12	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Quad	Scales	1	Door 2	1	1	1		1		1	1			4	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Quad	Scales	1	Back door into reception		1			1		1				ETR		18/6S, 22/2, 22/4, 18/4, 16/2	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Scales	1	Side door in stairway by study		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Scales	1	In stairway to dumpster area		1				1	1				ETR	Keyed Staff access.	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Scales	1	From kitchen vestibule		1				1	1				ETR	Keyed Staff access.	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Scales	1	From Unassigned rm by Kitch		1				1	1				ETR	Keyed Staff access.	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Scales	1	at residence life suite		1				1	1				ETR	Keyed Staff access.	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Scales	1	door at dining hall		1				1	1				ETR	Keyed Staff access.	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Scales	B	Door by Cybersmith room		1				1	1				ETR	Keyed Staff access.	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Scales	B	Door to Telefund area		1				1	1				ETR	Keyed Staff access.	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Sessions	1	Door 1	1	1	1		1		1				4	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Campus Ctr	Sessions	1	Door 2	1	1			1		1				10		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Campus Ctr	Sessions	1	Side to Laundry room		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Sessions	1	Front Door		1				1	1				ETR	Egress	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Sessions	1	Door to Basement		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Sessions	1	Side door from TV room to Porch									1		ETR	No Cable Needed		No Mounting Hardware Needed
Campus Ctr	Sessions Annex	1	Door 1	1	1			1		1				7		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Campus Ctr	Sessions Annex	1	Door 2	1	1		1	1		1			1	12	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Campus Ctr	Sessions Annex	1	Back door		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Sessions Annex	1	Side door to Porch		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Sessions Annex	B	Hatchway		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Talbot	1	Door 1	1	1			1		1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Talbot	1	Door 2	1	1			1		1				27		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Talbot	B	Door 3	1	1			1		1				29	Bike Kitchen	18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Upper Elm	Talbot	B	Door under side Porch		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Upper Elm	Talbot	B	Double Door to side porch									1		ETR	No Cable Needed		No Mounting Hardware Needed
Upper Elm	Talbot	B	Door to sub-basement mech		2				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Tenney	1	Door 1	1	1			1		1				7	No Front door reader per Res Life	18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Campus Ctr	Tenney	1	Door 2	1	1	1		1		1				30	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang

Residence House Door Schedule - for bid 11-22-2011 - Revised for Addendum #1 12-2-2011

Area	Building	Floor	Door # Location	New Reader	New Door Contact	New ADA Door Operator	Existing Door Operator	Request to exit in hardware	Request To Exit Infrared	Local Alarm	Remove and Salvage Existing reader	Secure	Key switch to paddle	Hardware Group	Notes	Cable Requirements	Mounting Requirements
Campus Ctr	Tenney	1	Door 3	1	1					1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Tyler	1	Door 1	1	1			1		1	1			5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Tyler	1	Door 2	1	1		1	1		1	1		1	12	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Green Street	Tyler	1	Door 3	1	1			1		1				11		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Tyler	1	Door K	1	1			1		1				23		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Tyler	1	Back door to dining rm		1				1	1				ETR	How is this door used today?	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Green Street	Tyler	B	Door to Hatchway		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Lower Elm	Unity House	1	Door 1	1	1	1		1		1				10	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Washburn	1	Door 1	1	1		1	1		1			1	9	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Green Street	Washburn	1	Door 2	1	1			1		1				5		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Washburn	1	Door 3	1	1			1		1	1			5	24 hour computing lab	18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Washburn	B	Door 4	1	1			1		1				6		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Green Street	Washburn	1	2nd door to front porch		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Wesley	1	Door 1	1	1		1	1		1			1	31	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Campus Ctr	Wesley	1	Door 2	1	1			1		1				7		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Campus Ctr	Wesley	1	Door 3	1	1	1		1		1	1			4	Entrance to Ctr for Gender/Sexuality	18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Campus Ctr	Wesley	B	Back door to basement		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Wilder	1	Door 1	1	1			1		1	1			14		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Wilder	1	Door 2	1	1		1	1		1			1	15	ADA Entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Paddle - Single Gang
Quad	Wilder	1	Door 3	1	1			1		1				7		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Wilder	1	Door K	1	1			1		1				14		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Wilder	1	Kitchen to courtyard		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Wilder	1	Door to back stairs		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Wilder	1	French door to courtyard									1		ETR	Keyed staff access.	No Cable Needed	No Mounting Hardware Needed
Quad	Wilder	1	French door to courtyard									1		ETR	Keyed staff access.	No Cable Needed	No Mounting Hardware Needed
Quad	Wilder	B	Pass-thru under Arch									1		ETR	Internal door, leave locked.	No Cable Needed	No Mounting Hardware Needed
Quad	Wilder	B	Back corner by generator room		1				1	1				ETR	Keyed staff access.	22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Wilder	B	Corridor to external stairs		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Wilson	1	Door 1	1	1			1		1	1			1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Wilson	1	Door 2	1	1			1		1				1		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Wilson	1	DoorK	1	1			1		1				7		18/6S, 22/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang
Quad	Wilson	2	Fire Escape between 233 & 234		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Wilson	1	Door to back stair		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Wilson	1	Door from hall off kitchen		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Wilson	1	Door off stair 100ST2		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Wilson	B	Door to basement east		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Quad	Wilson	B	Door to basement west		1				1	1				ETR		22/2, 22/4, 18/4	Local Alarm - Double Gang, Infrared REX - Single Gang
Campus Ctr	Ziskind	1	Door 1	1	1		1	1		1	1		1	32	ADA entrance	18/6S, 22/2, 18/2, 22/4, 18/4, 16/2	Card Reader - Single Gang, Local Alarm - Double Gang, Keyswitch - Single Gang
Totals				111	223	19		106	217	26	26	22					

Cable Legend

18/6S	18 Gauge, 6 Conductor, Twisted, Shielded
22/2	22 Gauge, 2 Conductor, Twisted
22/4	22 Gauge, 4 Conductor, Twisted
18/2	18 Gauge, 2 Conductor, Twisted
18/4	18 Gauge, 4 Conductor, Twisted
16/2	16 Gauge, 2 Conductor, Twisted

NOTE: Electrical contractor to provide plenum rated cable for any cable that will be run in plenum rated ceilings.